



# Intertek Testing Services

## ETL SEMKO

September 22, 2003

Rocky Mountain Stoneworks Ltd.  
26076 – 31B Avenue  
Aldergrove, B.C. V4W 2Z6

Attention: Mr. Robert McIntosh

Dear Sir:

**Re: Project No. 3041989**

On September 18, 2003, Intertek Testing Services NA Ltd./Warnock Hersey conducted a test program on behalf of Rocky Mountain Stoneworks Ltd. The purpose of the testing was to determine whether or not the submitted samples of manufactured stone would meet the requirements of CAN/ULC S114, *Standard Method of Test for Determination of Non-Combustibility in Building Materials*.

After the specimens were conditioned, they were weighed and then tested in accordance with the test standard. This standard states that: the mean of the maximum temp. rise for the three specimens does not exceed 36°C; and there is no flaming of any of the three specimens during the last 14 min. and 30 s. of the test; and the maximum loss of mass of any of the three specimens does not exceed 20%. The results of the tests are as follows:

Sample No.	Temp. Rise Above Initial (°C)	Flaming After 30 Secs.	Weight Loss (%)
1	0	No	7.5
2	0	No	7.6
3	0	No	7.4
<b>Average</b>	<b>0</b>	<b>No</b>	<b>7.5</b>



The samples of manufactured stone, submitted by Rocky Mountain Stoneworks Ltd., therefore met the requirements of CAN/ULC S114, *Standard Method of Test for Determination of Non-Combustibility in Building Materials*.



**INTERTEK TESTING SERVICES NA LTD.**

Tested and Reported by:

Reviewed by



*GP*

*CR*



Greg Philp  
Technician – Construction Products Testing

Cam Robinson, P.Eng.  
Manager – Construction Products Testing

GP/bjm



C:\Documents and Settings\Brenda\My Documents\ITS-DATA\490-WP\RPT\2003 - 493 Rpts\rockymtn.3041989.sep-03.doc



**Intertek Testing Services NA Ltd.**  
211 Schoolhouse Street, Coquitlam, BC V3K 4X9 Canada  
Telephone 604-520-3321 Fax 604-524-9186 Home Page www.etlsemko.com

